



135 Fox Road, Suite A Knoxville, TN 37922
800-489-8274 Phone 865-690-1558 Fax 800-323-4034

September 4, 2001

Specification for Radiant Floor Company Heat Exchanger Tubing

Material: Potable water rated cross-linked polyethylene (PEX) with FDA approved color and UV protection additives.

Dimensions: Pipe to be made to ASTM D2239 specification

ID 0.824" +0.010"-0.015"

Wall thickness 0.072" +.020"-0.0"

Print: To be marked every five feet:

7/8" Dura-Poly XL Radiant Floor Company Heat Exchanger Tubing 100 PSI @ 120deg
90 PSI @ 135deg PEX 3/4 SIDR 11.5 ASTM D2239 xx mmddy

Operating pressure and temperature ratings:

60 psi at 180 deg F

90 psi at 135 deg F

100 psi at 120 deg F

For CPI by,

A handwritten signature in black ink, appearing to read "Martin Cumpston", written over a white background.

Martin Cumpston